

Certificate



Certificate no.

CU 72200373 01

License Holder:

Gateview Technologies
3207 Rogers Rd. #205
Wake Forest NC 27587
USA

Test report no.: USA-TN 31985181 001

Client Reference: Lynn Schultz

Tested to: UL 60950-1:2007 R10.14

CAN/CSA-C22.2 NO.60950-1-07+A1:2011+A2:2014

Certified Product: Power Distribution Unit

License Fee - Units

Model Designation:

7

- 1) PL01cdegt-xyz, PD01cdegt-xyz, UP01cdegt-xyz;
 - 2) PL02cdegt-xyz, PD02cdegt-xyz, UP02cdegt-xyz;
 - 3) PL03cdegt-xyz, PD03cdegt-xyz, UP03cdegt-xyz;
 - 4) PL04cdegt-xyz, PD04cdegt-xyz, UP04cdegt-xyz;
 - 5) PL05cdegt-xyz, PD05cdegt-xyz, UP05cdegt-xyz;
 - 6) PL06cdegt-xyz, PD06cdegt-xyz, UP06cdegt-xyz;
- (c=A,B; d=0-99; e=A-C; g=3-10; t=A-Z; x,y=0-2; z=0-1)

Rated Voltage: 1),3) AC 120/208V, 50-60Hz;

2),4) AC 240/415V, 50-60Hz;

5),6) AC 208V, 50-60Hz

contd.

7

Appendix: 1, 1-5

Licensed Test mark:



Date of Issue

(day/mo/yr)

11/02/2020

Certificate



Certificate no.

CU 72200373 02

License Holder:

Gateview Technologies
3207 Rogers Rd. #205
Wake Forest NC 27587
USA

Test report no.: USA-TN 31985181 001

Client Reference: Lynn Schultz

Tested to: UL 60950-1:2007 R10.14

CAN/CSA-C22.2 NO.60950-1-07+A1:2011+A2:2014

Certified Product: Power Distribution Unit

License Fee - Units

contd.

Rated Current: 1), 2), 5) 16A;
3), 4), 6) 24A

Protection Class: I

Licensed Test mark:



Date of Issue

(day/mo/yr)

11/02/2020

Date : 2020/02/15

Gateview Technologies
3207 Rogers Rd. #205
Wake Forest NC 27587
USA

Attn:

Re. : CU US + Canada Certificate

Type of Equipment : Power Distribution Unit
Model Designation : See Certificate
Certificate No. : CU 72200373 0002
File No. : 31985181 001
Engineer/Contact : Tuong Ngu
Standard(s) : UL 60950-1:2007 R10.14
CAN/CSA-C22.2 NO.60950-1-07+A1:2011+A2:2014

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72200373 0002.
It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document.
For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body

Dipl.-Ing. M. Glagla
QA Certification Officer

Enclosure

TUV Rheinland
of North America, Inc.
San Francisco Office

1279 Quarry Lane
Suite A
Pleasanton, CA 94566

Tel 925-249-9123
Fax 925-249-9124
Mail info@us.tuv.com

North American Headquarters

12 Commerce Road
Newtown, CT 06470

Tel 203-426-0888
Fax 203-426-4009
Toll Free TUV-RHEINLAND
Web www.tuv.com

Member of
TUV Rheinland Group